

# Memo

**To:** Conco= 510 N. Sherman  
**From:** Randy Lyman *Randy*  
**Date:** 11/30/98

Gene Pabst and I received building plans on 11/25/98 for a new truck wash in the northwest corner of the old quarry. Our concerns were:

1. No roof covering facility.
2. Need a meter on line discharging to sanitary sewer from "clean water" part of system for sewer billing.
3. Questioned the need to discharge to sewer, why not the quarry?

cc: Gene Pabst  
Randy: file copy  
Misc. file, by address

510 N. SHERMAN